

The following sample was submitted and identified on behalf of the client as:

TEST REPORT

COMMISSION REGULATION (EU) No 811/2013

of 18 February 2013

supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to the energy labelling of space heaters, combination heaters, packages of space heater, temperature control and solar device and packages of combination heater, temperature control and solar device

COMMISSION REGULATION (EU) No 813/2013 of 2 August 2013

implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters

GZES201203564132 Report Reference No.....

Bavid Lei /Project engineer Tested by (name + signature).....:

Sky Lin /Reviewer Approved by (+ signature)

2021-01-11 Date of issue Total number of pages..... 25 pages

Testing Laboratory SGS-CSTC Standards Technical Services Co., Ltd. Shunde

Branch

Building 1, European Industrial Park, No.1, Shunhenan Road, Address.....

Wusha, Daliang, Shunde District, Foshan, Guangdong, China

Applicant's name NuLite New Energy (Guangzhou) Co., Ltd.

506 No.16 North Red Cotton avenue Xiuquan Street Huadu District Address.....:

Guangzhou City China

Test specification:

Standard COMMISSION REGULATION (EU) No 811/2013; (EU) No

813/2013

EN 14825: 2018

Test procedure....: STR: EU Directive 2009/125/EC

Non-standard test method..... None

Test Report Form No..... 811/2013_01/813/2013_1

Test Report Form(s) Originator: SGS-CSTC Master TRF..... 2015-04-27

This test report is issued under SGS general terms of delivery (available on request and accessible at www.sgs.com). Attention is drawn to the limitations of liability, indemnification and jurisdictional issues defined therein. Unless otherwise stated: (a) the results shown in this document refer only to the sample(s) tested and (b) such sample(s) are retained for three months. This document cannot be reproduced except in full, without prior approval of SGS.

Any unauthorized alteration, forgery or falsification of the content or appearance of this report is unlawful and offenders may be prosecuted to the fullest extent of the law

Test item description: DC Inverter Heat Pump Trade Mark **NULITE NEW ENERGY** Manufacturer....: Same as applicant Model/Type reference..... NL-BKDX50-200II/R32 380 V,3N~,50HZ,IPX4; details refer to marking plates Ratings.....

Same as applicant Factory.....

TRF No.: 811/2013_01/ 813/2013_1



Page 2 of 25 Report No.: GZES201203564132

Summary of testing:

Tests performed (name of test and test clause):

COMMISSION REGULATION (EU) No 811/2013 and COMMISSION REGULATION (EU) No

813/2013. EN 14825: 2018

The test voltage: 400 V,3N~

Testing location:

1/F., of No.1 Jusheng Road, Ronggui Hongxing Residential Committee, Shunde, Foshan, Guangdong, China

Copy of marking plate

The marking plate is only the draft.

DC Inverter Hea	at Pump
Model	NL-BKDX50-200II/R32
Rated of waterproof	IPX4
Rated of Elc. leakage protection	I Class
Power supply	380V-3N-Inverter
Max water pump head	8M
Expansion tank capacity	5L
Rated input power	7500W
Rated input current	12.9A
Auxilary element power	3000W
Auxilary element current	14A
Heating capacity	5500W-21000W
Hot water capacity	4500W-20000W
Cooling capacity	4800W-14500W
Heating input power	2000-5500W
Hot water input power	2000-5500W
Cooling input power	2000-5500W
Rated flow rate	3.5m ³ /h
Max water temperature	60°C
Refrigeration	R32/2300g
Net weight	150KG
Noise	≤52dB(A)
Max working pressure	4.2MPa



Page 3 of 25 Report No.: GZES201203564132

Test item particulars

Classification of installation and use Fixed appliance

Supply Connection...... Connected to fixed wiring

Possible test case verdicts:

- test object does meet the requirement...... P (Pass)

- test object does not meet the requirement...... F (Fail)

Testing.....

General remarks:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory. "(see Enclosure #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.

This document is issued by the company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated: (a) the results shown in this document refer only to the sample(s) tested and (b) such sample(s) are retained for 3 months. This document cannot be reproduced except in full, without prior approval of the company.

General product information:

Heap pump for space heating used.



	COMMISSION REGULATION (EU) No 813/2013						
CI.	Requirement-Test Result-Remark	Verdict					
	Ecodesign requirements	T -					
ANNEX I	Definitions applicable for Annexes II to V	Р					
ANNEX II	Ecodesign requirements	Р					
1. (a)	From 26 September 2015 the seasonal space heating energy efficiency and useful efficiencies of heaters shall not fall below the following values:	Р					
	Fuel boiler space heaters with rated heat output ≤ 70 kW and fuel boiler combination heaters with rated heat output ≤ 70 kW, with the exception of type B1 boilers with rated heat output ≤ 10 kW and type B1 combination boilers with rated heat output ≤ 30 kW:	N/A					
	The seasonal space heating energy efficiency shall not fall below 86 %.	N/A					
	Type B1 boilers with rated heat output ≤ 10 kW and type B1 combination boilers with rated heat output ≤ 30 kW:	N/A					
	The seasonal space heating energy efficiency shall not fall below 75 %.	N/A					
	Fuel boiler space heaters with rated heat output > 70 kW and ≤400 kW and fuel boiler combination heaters with rated heat output > 70 kW and ≤ 400 kW:	N/A					
	The useful efficiency at 100 % of the rated heat output shall not fall below 86 %, and the useful efficiency at 30 % of the rated heat output shall not fall below 94 %.	N/A					
	Electric boiler space heaters and electric boiler combination heaters:	N/A					
	The seasonal space heating energy efficiency shall not fall below 30 %.	N/A					
	Cogeneration space heaters:	N/A					
	The seasonal space heating energy efficiency shall not fall below 86 %.	N/A					
	Heat pump space heaters and heat pump combination heaters, with the exception of low-temperature heat pumps:						
	The seasonal space heating energy efficiency shall not fall below 100 %.	Р					
	Low-temperature heat pumps:	N/A					
	The seasonal space heating energy efficiency shall not fall below 115 %.	N/A					
(b)	From 26 September 2017 the seasonal space heating energy efficiency of electric boiler space heaters, electric boiler combination heaters, cogeneration space heaters, heat pump space heaters and heat pump combination heaters shall not fall below the following values:	Р					
	Electric boiler space heaters and electric boiler combination heaters:	N/A					
	The seasonal space heating energy efficiency shall not fall below 36 %.	N/A					
	Cogeneration space heaters:	N/A					
	The seasonal space heating energy efficiency shall not fall below 100 %.	N/A					



Page 5 of 25 Report No.: GZES201203564132

	-			Pag	je 5 ot 2	25			R	eport in	0 GZ	.632012	03564132
		COM	/IISSIO	N RE	GULA 1	TION (E	EU)	No 81	3/2	013			
CI.	Requirement-T	est						Resu	t-Re	emark			Verdict
	Heat pump spa of low-tempera				t pump	combir	natio	n hea	ters	, with th	ne exc	ception	Р
	The seasonal s	space h	neating	energ	y efficie	ncy sh	all						Р
	Low-temperatu	ire hea	t pumps	S :									N/A
	The seasonal s		neating	energ	y efficie	ency sh	all						N/A
2.	REQUIREMEN ENERGY EFF			ER H	EATING	3							N/A
(a)		From 26 September 2015 the water heating energy efficiency of combination heaters shall not fall below the following values:											
	Declared load profile	3XS	XXS	XS	S	M	I	. 2	(L	XXL	3XL	4XL	N/A
	Water heating energy efficiency	22 %	23 %	26 %	26 %	30 %	30	% 30) %	32 %	32 %	32 %	
(b)	From 26 September 2017 the water heating energy efficiency of combination heaters shall not fall below the following values:												N/A
	Declared load profile	3XS	xxs	XS	S	М	I		KL	XXL	3XL	4XL	N/A
	Water heating energy efficiency	32 %	32 %	32 %	32 %	36 %	37	% 3	8 %	60 %	64 %	64 %	
3	REQUIREMENTS FOR SOUND POWER LEVEL												No testing
	From 26 Septe heat pump cor											rs and	No testing
	Rated heat output	≤ 6 kW	Rated heat	output ≥	> 6 kW and	Rated hea		out > 12 k 0 kW	W and		eat outpo and ≤ 70	ut > 30 kW kW	No testing
	level (L_{WA}), por indoors	Sound wer level (L _{WA}), utdoors	Sound power le (L _{WA}), indoor	evel po	Sound ower level (L _{WA}), outdoors	Soun power (L _{WA} indoo	level),	Sou power (L _W	level 4),	Sour power (L _W ,	level),	Sound power level (L _{WA}), outdoors	
	60 dB	65 dB	65 dB		70 dB	70 d	В	78 (lB	80 d	В	88 dB	
4.	REQUIREMEN NITROGEN O		R EMIS	SSION	IS OF								N/A
5	REQUIREMEN	NTS FC	R PRO	DUC	ΓINFOF	RMATI	NC						Р
	From 26 Septe					oduct							Р
(a)	the instruction and free acces authorised rep contain the foll	s webs resenta	ites of ratives ar	manuf nd imp	acturer	s, their	ers,						Р
	for boiler space and cogenerat parameters se calculated in a	e heate ion spa t out in	rs, boile ce heat Table 1	er con ers, th	ne techr Isured a	nical	ers						N/A



Report No.: GZES201203564132



COMMISSION REGULATION (EU) No 813/2013 CI. Requirement-Test Result-Remark Verdict Р for heat pump space heaters and heat pump combination heaters, the technical parameters set out in Table 2, measured and calculated in accordance with Annex III; any specific precautions that shall be taken when Р the heater is assembled, installed or maintained; for type B1 boilers and type B1 combination boilers. N/A their characteristics and the following standard text: 'This natural draught boiler is intended to be connected only to a flue shared between multiple dwellings in existing buildings that evacuates the residues of combustion to the outside of the room containing the boiler. It draws the combustion air directly from the room and incorporates a draught diverter. Due to lower efficiency, any other use of this boiler shall be avoided and would result in higher energy consumption and higher operating costs: for heat generators designed for heaters, and N/A heater housings to be equipped with such heat generators, their characteristics, the requirements for assembly, to ensure compliance with the ecodesign requirements for heaters and, where appropriate, the list of combinations recommended by the manufacturer; information relevant for disassembly, recycling N/A and/or disposal at end-of-life; (b) the technical documentation for the purposes of Р conformity assessment pursuant to Article 4 shall contain the following elements: Ρ the elements specified in point (a): Р for heat pump space heaters and heat pump combination heaters where the information relating to a specific model comprising a combination of indoor and outdoor units has been obtained by calculation on the basis of design and/or extrapolation from other combinations, the details of such calculations and/or extrapolations, and of any tests undertaken to verify the accuracy of the calculations, including details of the mathematical model for calculating the performance of such combinations and details of the measurements taken to verify this model; (c) N/A the following information shall be durably marked on the heater: if applicable, 'type B1 boiler' or 'type B1 combination N/A boiler'; for cogeneration space heaters, the electrical N/A capacity. ANNEX III Measurements and calculations



Page 7 of 25 Report No.: GZES201203564132

	Page 7 of 25	Report No.: GZESZU1	20000-102
	COMMISSION REGULATION (EU)	No 813/2013	
CI.	Requirement-Test	Result-Remark	Verdict
1	For the purposes of compliance and verification of compliance with the requirements of this Regulation, measurements and calculations shall be made using harmonised standards the reference numbers of which have been published in the <i>Official Journal of European Union</i> , or other reliable, accurate and reproducible method, which takes into account the generally recognised state of the art methods, and whose results are deemed to be of low uncertainty. They shall fulfil all of the following technical parameters.	EN 14825:2018 was used	Р
2	General conditions for measurements and calculations		Р
	(a) For the purposes of the measurements set out in points 2 to 5, the indoor ambient temperature shall be set at 20 $^{\circ}$ C \pm 1 $^{\circ}$ C.		Р
	(b) For the purposes of the calculations set out in points 3 to 5, consumption of electricity shall be multiplied by a conversion coefficient CC of 2,5.		Р
	(c) Emissions of nitrogen oxides shall be measured as the sum of nitrogen monoxide and nitrogen dioxide, and expressed in nitrogen dioxide.		N/A
	(d) For heaters equipped with supplementary heaters, the measurement and calculation of rated heat output, seasonal space heating energy efficiency, water heating energy efficiency, sound power level and emissions of nitrogen oxides shall take account of the supplementary heater.		Not Check
	(e) Declared values for rated heat output, seasonal space heating energy efficiency, water heating energy efficiency, sound power level and emissions of nitrogen oxides shall be rounded to the nearest integer.		Not Check
	(f) Any heat generator designed for a heater, and any heater housing to be equipped with such a heat generator, shall be tested with an appropriate heater housing and heat generator, respectively.		N/A
3	Seasonal space heating energy efficiency of boiler space heaters, boiler combination heaters and cogeneration space heaters		N/A
	The seasonal space heating energy efficiency η s shall be calculated as the seasonal space heating energy efficiency in active mode η son, corrected by contributions accounting for temperature controls, auxiliary electricity consumption, standby heat loss, ignition burner power consumption (if applicable) and, for cogeneration space heaters, corrected by adding the electrical efficiency multiplied by a conversion coefficient CC of 2,5.		N/A
4	Seasonal space heating energy efficiency of heat pump space heaters and heat pump combination heaters		Р



Report No.: GZES201203564132



COMMISSION REGULATION (EU) No 813/2013 CI. Requirement-Test Result-Remark Verdict (a)For establishing the rated coefficient of P performance COP rated or rated primary energy ratio PER rated, the sound power level or emissions of nitrogen oxides, the operating conditions shall be the standard rating conditions set out in Table 3 and the same declared capacity for heating shall be used. (b)The active mode coefficient of performance Р SCOP on or active mode primary energy ratio SPER on shall be calculated on the basis of the part load for heating Ph(T j), the supplementary capacity for heating sup(T j) (if applicable) and the bin-specific coefficient of performance COPbin(T j) or bin-specific primary energy ratio PERbin(T j), weighted by the bin-hours for which the bin conditions apply, using the following conditions: - the reference design conditions set out in Table P 4; P the European reference heating season under average climate conditions set out in Table 5; - if applicable, the effects of any degradation of Р energy efficiency caused by cycling depending on the type of control of the heating capacity. (c)The reference annual heat demand Q H shall be Р the design load for heating Pdesignh multiplied by the annual equivalent active mode hours H HE of 2 (d)The annual energy consumption Q HE shall be P calculated as the sum of: the ratio of the reference annual heating demand Р Q H and the active mode coefficient of performance SCOP on or active mode primary energy ratio SPER on and the energy consumption for off, thermostat-off, Ρ standby, and crankcase heater mode during the heating season. (e)The seasonal coefficient of performance SCOP Р or seasonal primary energy ratio SPER shall be calculated as the ratio of the reference annual heat demand Q H and the annual energy consumption Q P (f)The seasonal space heating energy efficiency n s shall be calculated as the seasonal coefficient of performance SCOP divided by the conversion coefficient CC or the seasonal primary energy ratio SPER, corrected by contributions accounting for temperature controls and, for water-/brine-to-water heat pump space heaters and heat pump combination heaters, the electricity consumption of one or more ground water pumps. Water heating energy efficiency of combination heaters 5 N/A The water heating energy efficiency n wh of a N/A combination heater shall be calculated as the ratio between the reference energy Q ref of the declared load profile and the energy required for its generation under the following conditions:



Page 9 of 25 Report No.: GZES201203564132

		COMMISSIO	N REGULATION	ON (EU) No	813/2013						
CI.	Requirement-	Test		Re	sult-Remark		Verdict				
		ents shall be ca et out in Table 7		the			N/A				
		ents shall be ca ment cycle as fo		a 24-			N/A				
	— 00:00 to 06	6:59: no water di	aw-off;								
	— from 07:00 declared load	: water draw-off profile;	s according to	the							
	— from end of water draw-of	from end of last water draw-off until 24:00: no ater draw-off;									
		ed load profile sl the load profile d profile;		kimum			N/A				
		ımp combination									
	— heat pump combination heaters shall be tested under the conditions set out in Table 3;										
	heat pump combination heaters which use ventilation exhaust air as the heat source shall be tested under the conditions set out in Table 6.										
Гable 3		Table 3									
	Standard rating conditions for heat pump space heaters and heat pump combination heaters										
		Outdoor heat exchanger Indoor heat exchanger									
	Heat source	Inlet dry bulb (wet bu		eaters and heat pum aters, except low- e heat pumps		ure heat pumps					
		- Composition	Inlet temperature	Outlet temperatur	e Inlet temperature	Outlet temperature					
	Outdoor air	+ 7 °C (+ 6 °C)									
	Exhaust air	+ 20 °C (+ 12 °C)									
		Inlet/outlet temperature	+ 47 °C	+ 55 ℃	+ 30 °C	+ 35 °C					
	Water	+ 10 °C/+ 7 °C									
	Brine	0 °C/− 3 °C									
Table 4	Reference design	Table 4 Reference design conditions for heat pump space heaters and heat pump combination heaters, temperatures in dry bulb air temperature (wet bulb air temperature indicated in brackets)									
	Reference desi	ign temperature	Bivalent temp	erature	Operation limit temperature						
	Tde	signh	T_{biv}		ТО	L					
	- 10 (-	- 11) °C	maximum -	+ 2 ℃	maximu	m – 7 °C					



Page 10 of 25 Report No.: GZES201203564132

CI.	Requirement-Test Result-Remark										Verdict
Table 5	European reference heating season	under a	iverage c	Table 5 limate co pination l	nditions neaters				ers and he	at pump	Р
				T _j [°C]			H _j [h/annum]				
	1 to 20		12	- 30 to -	11		0				
	21		- 10					1		*	
	22			- 9				2	5		
	23			- 8				2	3		
	24			- 7				24	4	-	
	25			- 6				27	7		
	26			- 5				68	8		
	27			- 4				9	1		
	28			- 3				89	9		
	29			- 2				16	5		
	30			- 1			173				
	31			0			240				
	32			1				28	0		
	33			2			320				
	34		3					357			
	35		4					356			
	36		5				303				
	37		6					330			
	38			7			326				
	39		8					348			
	40			9				33	5		
	41			10				31	5	-	
	42			11				21	5	-	
	43			12				16	9		
	44	2.		13				15	1		
	45			14				10	15		
	46			15				74	4		
	Tot		4 910								
able	Maximum vent	Table 6 Maximum ventilation exhaust air available [m³/h], at humidity of 5,5 g/m³									
	Declared load profile	XXS XS S M I				L	XL	XXL	3XL	4XL	
	Maximum ventilation exhaust air available	109	128	128	159	190	870	1 021	2 943	8 830	

Report No.: GZES201203564132



COMMISSION REGULATION (EU) No 811/2013 CI. Requirement-Test Result-Remark Verdict P ANNEX II Energy efficiency classes Р The seasonal space heating energy efficiency class of a heater, with the exception of low-temperature heat pumps and heat pump space heaters for lowtemperature application, shall be determined on the basis of its seasonal space heating energy efficiency as set out in Table 1. N/A The seasonal space heating energy efficiency classes of a low-temperature heat pump and a heat pump space heater for low-temperature application shall be determined on the basis of its seasonal space heating energy efficiency as set out in Table 2. Ρ The seasonal space heating energy efficiency of a heater shall be calculated in accordance with points 3 and 4 of Annex VII, for heat pump space heaters, heat pump combination heaters and lowtemperature heat pumps under average climate conditions. Table1 Table 1 Seasonal space heating energy efficiency classes of heaters, with the exception of low-temperature heat pumps and heat pump space heaters for low-temperature application Seasonal space heating energy efficiency class Seasonal space heating energy efficiency η_s in % $\eta_s \ge 150$ A++ $125 \le \eta_s < 150$ A⁺ $98 \le \eta_s < 125$ $90 \le \eta_s < 98$ A В $82 \le \eta_s < 90$ C $75 \le \eta_s < 82$ D $36 \le \eta_s < 75$ $34 \le \eta_s \le 36$ Е F $30 \le \eta_s < 34$ $\eta_{s} < 30$ Table 2 Table 2 Seasonal space heating energy efficiency classes of low-temperature heat pumps and heat pump space heaters for low-temperature application Seasonal space heating energy efficiency class Seasonal space heating energy efficiency η_s in % $\eta_s \ge 175$ A++ $150 \le \eta_s < 175$ A^{+} $123 \le \eta_s < 150$ A $115 \le \eta_s \le 123$ В $107 \le \eta_s \le 115$ C $100 \le \eta_s \le 107$ D $61 \le \eta_s \le 100$ E $59 \le \eta_s \le 61$ F $55 \le \eta_s < 59$ $\eta_{s} < 55$ G



Page 12 of 25 Report No.: GZES201203564132

2	WATER HEATING ENERGY EFFICIENCY CLASSES	N/A
	The water heating energy efficiency class of a combination heater shall be determined on the basis of its water heating energy efficiency as set out in Table 3.	N/A



Page 13 of 25 Report No.: GZES201203564132

Table 1:						Р			
Information requi		neat pump	space h	eaters and heat pump					
(the number of dec to which the inform			the pre	cision of reporting) Inform	mation to ider	ntify the mod	del(s)		
Air-to-water heat po	ump: [yes/no]			Yes					
Water-to-water hea	at pump: [yes/	no]		No					
Brine-to-water heat	pump: [yes/r	10]		No					
Low-temperature h	eat pump: [ye	es/no]		No					
Equipped with a su	pplementary	heater: [yes	/no]	Yes					
Heat pump combin	ation heater:	[yes/no]		No					
Parameters shall be temperature applicate temperature heat per heat pumps, parametemperature applications.	ation, except numps. For low neters shall be	for low- v- temperati		Parameters shall be do conditions.	eclared for av	verage clima	ate		
Medium-temperatu	re	Y	Average (mandatory)		Y				
Low-temperature a	pplication	N		Warmer (if designated	N				
	Colder (if designated)					N			
Item	symbol	value	unit	item	symbol	value	unit		
Rated heat output (*)	Prated	12,83	kW	Seasonal space heating energy efficiency	ηѕ	128	%		
Declared capacity temperature 20 °C				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature T j					
T j = -7 °C	Pdh	11,35	kW	T j = -7 °C	COPd	1,86	-		
T j = + 2 °C	Pdh	7,03	kW	T j = + 2 °C	COPd	3,52	-		
T j = + 7 °C	Pdh	4,70	kW	T j = + 7 °C	COPd	4,15	-		
T j = + 12 °C	Pdh	2,69	kW	T j = + 12 °C	COPd	6,10	-		
T j = bivalent temperature	Pdh	11,35	kW	T j = bivalent temperature	COPd	1,86	-		
T j = operation limit temperature	Pdh	13,07	kW	T j = operation limit temperature	COPd	1,48	-		
For air-to-water heat pumps: T j = - 15°C (if TOL < - 20°C)	Pdh	N/A	kW	For air-to-water heat pumps: T j = -15°C (if TOL < -20°C)		N/A	-		
Bivalent temperature	T biv	-7	°C	For air-to-water heat pumps: Operation limit temperature	TOL	-10	°C		
Cycling interval capacity for heating	Pcych	N/A	kW	Cycling interval efficiency	COPcyc	N/A	kW		
Degradation co-	Cdh	0,9	_	Heating water	W _{TOL}	-	°C		



Page 14 of 25 Report No.: GZES201203564132

efficient (**)				operating limit temperature					
Power consumption mode	n in modes oth	ner than act	ive	Supplementary heater					
Off mode	P _{OFF}	0,0144	kW	Rated heat output (*)	Psup	3	kW		
Thermostat-off mode	Рто	0,0569	kW	Type of energy input	E	Electric	•		
Standby mode	P _{SB}	0,0144	kW						
Crankcase heater mode	P _{CK}	0,040	kW						
Other items	,		•						
Capacity control	Variable		For air-to-water heat pumps: Rated air flow rate, outdoors	_	_	m 3 /h			
Sound power level, indoors/ outdoors	L _{WA}	52	dB	For water-/brine-to- water heat pumps: Rated brine or water	_	N/A	m 3 /h		
Emissions of nitrogen oxides	NO x	N/A	mg/ kWh	flow rate, outdoor heat exchanger					
Annual energy consumption	Q _{HE}	8068	KWh						
For heat pump con	nbination heat	er:	•				•		
Declared load profile		N/A		Water heating energy efficiency	η wh	N/A	%		
Daily electricity consumption	Q elec	N/A	kWh	Daily fuel consumption	Q fuel	N/A	kW h		
Contact details	NuLite New	Energy (Gu	angzhou	u) Co., Ltd.	1				
	506 No.16 No	North Red (Cotton a	venue Xiuquan Street I	Huadu Distric	t Guangzh	ou City		

^(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

^(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.



Page 15 of 25 Report No.: GZES201203564132

Test condition (Heating function / Average heating season in medium temperature application):

Voltage: <u>400 V,3N~</u> / frequency: <u>50</u> Hz; Indoor heat exchanger: variable outlet

Tj (bivalent temperature): _-7 °C; operating limit (TOL): _-10 °C;

Table 10 — Part load conditions for air-to-water(brine) units in medium temperature application for the reference heating seasons "A" = average, "W" = warmer and "C" = colder

518	Part I	Load R	atio			or heat anger	Indoor heat exchanger				
Condition		in %			temp	(wet) bulb erature °C	Fixed outlet °C	Variable outlet ^d °C			
	Formula	A	w	С	Outdoor air	Exhaust air	All climates	A	W	С	
A	(-7 - 16) / (T _{designh} -16)	88	n/a	61	-7(-8)	20(12)	a / 55	a / 52	n/a	a / 44	
В	(+2 - 16) / (T _{designh} -16)	54	100	37	2(1)	20(12)	a / 55	a / 42	a / 55	a / 37	
С	(+7 - 16) / (T _{designh} -16)	35	64	24	7(6)	20(12)	a / 55	a / 36	a / 46	a / 32	
D	(+12 - 16) / (T _{designh} -16)	15	29	11	12(11)	20(12)	a / 55	a / 30	a / 34	a / 28	
E	(TOL - 16)	(TOL - 16) / (Tdesignh - 16)			TOL	20(12)	a / 55	a / b	a / b	a / b	
F	(T _{biv} - 16) / (T _{designh} - 16)		$T_{ m biv}$	20(12)	a / 55	a / c	a / c	a / c			
G	(-15 - 16) / (T _{designh} -16)	n/a	n/a	82	-15	20(12)	a / 55	n/a	n/a	a / 49	

 $^{^{\}mathrm{a}}$ With the flow rate as determined at the standard rating conditions given in EN 14511-2 at 47/55 conditions for units with a fixed flow rate, and with a fixed delta T of 8 K for units with a variable flow rate. If for any of the test conditions the resulting flow rate is below the minimum flow rate then this minimum flow rate is used as a fixed flow rate with the outlet temperature for this test condition.

Remark: With the flow rate as determined at the standard rating conditions given in EN 14511-2 at 47/55 conditions.

Test data	(Average)):
-----------	-----------	----

General test conditions /Part-Load	Unit	A(-7)/W52 (88%)	A2/W42 (54%)	A7/W36 (35%)	A12/W30 (15%)	A(- 10)/W55. 3	A(- 7)/W52 (88%)
						(100%)	
		Α	В	С	D	E	F

 $^{^{\}rm b}$ Variable outlet shall be calculated by interpolation from $T_{\rm designh}$ and the temperature which is closest to the TOL

^c Variable outlet shall be calculated by interpolation between the upper and lower temperatures which are closest to the bivalent temperature.

 $^{^{}m d}$ If the variable outlet temperature is below the minimum of the operation range of the unit, this minimum should be considered.



Page 16 of 25 Report No.: GZES201203564132

		F	age 16 of 25		кероп и	0.: GZES201	203564132
Data collection period	hh:m m	02:00	02:00	02:00	02:00	02:00	02:00
The heat pump defrosts	-	No	No	No	No	No	No
Complete cycles	-	0	0	0	0	0	0
Barometric pressure	kPa	103,1	103,1	103,1	103,1	103,1	103,1
Voltage	V	400,0	400,0	400,0	400,0	400,0	400,0
Current	Α	9,28	3,06	1,75	0,68	13,56	9,28
Power input	W	6102,3	1996,8	1131,9	440,5	8836,8	6102,3
Test conditions indoor	unit		1			1	
Inlet Water temperature, DB	°C	45,70	37,96	33,17	28,53	47,65	45,70
Outlet Water temperature, DB	°C	52,08	41,91	35,81	30,04	55,00	52,08
Test conditions outdoo	l r unit						
Air inlet temperature, DB	°C	-7,00	2,00	7,00	12,02	-10,15	-7,00
Air outlet temperature, DB	°C	-8,16	1,08	6,00	10,97	-11,00	-8,16
Water flow	m³/h	1,53	1,53	1,53	1,53	1,53	1,53
Summary of test resu	ılt:			<u> </u>			
Test condition Hea	tina cana	city Hoa	ting nower	COP		Compres	ssor

Cummary or local rocalli					
Test condition	Heating capacity (kW)	Heating power input (kW)	СОР	Compressor frequency	
Α	11,3502	6,1023	1,8600	80 Hz	
В	7,0286	1,9968	3,5199	40 Hz	
С	4,6976	1,1319	4,1502	30 Hz	
D	2,6869	0,4405	6,0996	20 Hz	
E	13,0785	8,8368	1,4800	90 Hz	
F	11,3502	6,1023	1,8600	80 Hz	

Electric power consumptions	Unit	Value
Thermostat-off mode (P _{TO)}	kW	0,0487



Page 17 of 25

Standby mode(P _{SB})	kW	0,0144
Crankcase heater(P _{CK})	kW	0,0569
Off mode(P _{OFF})	kW	0,0144
Pdesignh	kW	12,830
SCOPon:	kWh/kWh	3,381
SCOP:	kWh/kWh	3,285
Q _H :	kWh	26508
Q _{HE} :	kWh	8068
$\eta_{s,h}$	%	128,4
Seasonal space heating energy efficiency classes: (According (EU)No 811/2013 Table 1)	A++	



Page 18 of 25 Report No.: GZES201203564132

Test condition (Heating function / Average heating season in low temperature application):

Voltage: 400 V,3N~ / frequency: 50 Hz;

Indoor heat exchanger: variable outlet

Tj (bivalent temperature): <u>-7 °C</u>; operating limit (TOL): <u>-10 °C</u>;

Table 8 — Part load conditions for air-to-water(brine) units in low temperature application for the reference heating seasons "A" = average, "W" = warmer and "C" = colder

6902	Part Load Ratio in %			or heat anger	Indoor heat exchanger			ger		
Condition			tempe	wet) bulb rature C	Fixed outlet °C	Variable outlet ^d °C		tlet ^d		
	Formula	Α	w	С	Outdoor air	Exhaust air	All climates	A	w	С
A	(-7 - 16) / (T _{designh} -16)	88	n/a	61	-7(-8)	20(12)	a / 35	a / 34	n/a	a / 30
В	(+2 - 16) / (T _{designh} -16)	54	100	37	2(1)	20(12)	a / 35	a / 30	a / 35	a / 27
С	(+7 - 16) / (T _{designh} -16)	35	64	24	7(6)	20(12)	a / 35	a / 27	a/31	a / 25
D	(+12 - 16) / (T _{designh} -16)	15	29	11	12(11)	20(12)	a / 35	a / 24	a / 26	a / 24
Е	(TOL - 16)	$/(T_{de}$	signh - 1	6)	TOL	20(12)	a / 35	a / b	a / b	a / b
F	(T _{biv} - 16)	$/(T_{de}$	signh - 1	6)	$T_{ m biv}$	20(12)	a / 35	a / c	a / c	a / c
G	(-15 - 16) / (T _{designh} -16)	n/a	n/a	82	-15	20(12)	a / 35	n/a	n/a	a / 32

 $^{^{\}rm a}$ With the flow rate as determined at the standard rating conditions given in EN 14511-2 at 30/35 conditions for units with a fixed flow rate, and with a fixed delta T of 5 K for units with a variable flow rate. If for any of the test conditions the resulting flow rate is below the minimum flow rate then this minimum flow rate is used as a fixed flow rate with the outlet temperature for this test condition.

Remark: With the flow rate as determined at the standard rating conditions given in EN 14511-2 at 30/35 conditions.

Test data(Average):

General test conditions	Unit	A(-7)/W34	A2/W30	A7/W2	A12/W24	A(-10)/	A(-
/Part-Load		(88%)	(54%)	7 (35%)	(15%)	W35,3	7)/W34 (88%)
						(100%)	
		Α	В	С	D	E	F

 $^{^{\}mathrm{b}}$ Variable outlet shall be calculated by interpolation from T_{designh} and the temperature which is closest to the TOL.

^c Variable outlet shall be calculated by interpolation between the upper and lower temperatures which are closest to the bivalent temperature.

^d If the variable outlet temperature is below the minimum of the operation range of the unit, this minimum should be considered.



Page 19 of 25 Report No.: GZES201203564132

		•	,				
Data collection period	hours	02:00	02:00	02:00	02:00	02:00	02:00
The heat pump defrosts	-	No	No	No	No	No	No
Complete cycles	-	0	0	0	0	0	0
Barometric pressure	kPa	103,1	103,1	103,1	103,1	103,2	103,1
Voltage	V	400	400	400	400	400	400
Current	А	6,04	2,91	2,48	0,59	7,60	6,04
Power input	W	3929,2	1877,0	955,4	382,0	4944,9	3929,2
Test conditions indoor u	nit						
Inlet Water temperature, DB	°C	29,93	27,47	25,16	23,06	31,18	29,93
Outlet Water temperature, DB	°C	33,93	30,18	27,02	24,05	35,24	33,93
Test conditions outdoor	unit						
Air inlet temperature, DB	°C	-7,06	1,97	6,90	11,98	-9,99	-7,06
Air outlet temperature, DB	°C	-7,83	1,00	6,03	11,06	-11,00	-7,83
Water flow	m³/h	2,68	2,68	2,68	2,68	2,68	2,68

Summary of test result:

Test condition	Heating capacity (kW)	Heating power input (kW)	СОР	Compressor frequency
Α	12,4594	3,9292	3,1710	80 Hz
В	8,4466	1,8770	4,5001	40 Hz
С	5,7973	0,9554	6,0679	30 Hz
D	3,0857	0,3820	8,0778	20 Hz
E	14,0881	4,9449	2,8490	90 Hz
F	12,4594	3,9292	3,1710	80 Hz

Electric power consumptions	Unit	Value
Thermostat-off mode (P _{TO)}	kW	0,0487
Standby mode(P _{SB})	kW	0,0144
Crankcase heater(P _{CK})	kW	0,0569
Off mode(P _{OFF})	kW	0,0144



Page 20 of 25

P _{designh}	kW	14,085
SCOPon:	kWh/kWh	4,729
SCOP:	kWh/kWh	4,560
Q _H :	kWh	29100
Q _{HE} :	kWh	6382
$\eta_{s,h}$	%	179,4
Seasonal space heating energy efficiency classes: (According (EU)No 811/2013 Table 2)	A+++	

Page 21 of 25 Report No.: GZES201203564132

Information of efficiency class according to (EU) No 811/2013			
Item	Measured value	Verdict	
Average (mandatory)		I	
Declared temperature application	Medium-temperature	_	
SCOP	3,285	_	
seasonal space heating energy efficiency η s; %	128,4	A++	
Annual energy consumption Q _{HE} ;(KWh)	8068	_	
Average (mandatory)			
Declared temperature application	Low-temperature	_	
SCOP	4,560	_	
seasonal space heating energy efficiency η s; %	179,4	A+++	
Annual energy consumption Q _{HE} ;(KWh)	6382	_	

⁽a) for heat pump space heaters and heat pump combination heaters using electricity:

$$\eta_s = (100/CC) \times SCOP - \Sigma F(i)$$

⁽¹⁾ For heat pump space heaters and heat pump combination heaters, the correction is F(1) = 3 %.

⁽²⁾ For water-/brine-to-water heat pump space heaters and heat pump combination heaters, the correction is F(2) = 5 %.



Information of efficiency class according to (EU) No 811/2013

Seasonal space heating energy efficiency classes of heaters, with the exception of low-temperature heat pumps and heat pump space heaters for low-temperature application

Report No.: GZES201203564132

Seasonal space heating energy efficiency class	Seasonal space heating energy efficiency η_{s} in %
A***	$\eta_s \ge 150$
A**	$125 \le \eta_s < 150$
A ⁺	$98 \le \eta_s < 125$
A	90 ≤ η _s < 98
В	$82 \le \eta_s < 90$
С	$75 \le \eta_s < 82$
D	$36 \le \eta_s < 75$
Е	$34 \le \eta_s < 36$
F	$30 \le \eta_s < 34$
G	$\eta_s < 30$

Seasonal space heating energy efficiency classes of low-temperature heat pumps and heat pump space heaters for low-temperature application

Seasonal space heating energy efficiency class	Seasonal space heating energy efficiency $\eta_{\scriptscriptstyle S}$ in %
A***	η _s ≥ 175
A**	$150 \le \eta_s < 175$
A^+	$123 \le \eta_s < 150$
A	$115 \le \eta_s < 123$
В	$107 \le \eta_s < 115$
С	$100 \le \eta_s < 107$
D	$61 \le \eta_s \le 100$
Е	$59 \le \eta_s < 61$
F	55 ≤ η _s < 59
G	$\eta_s < 55$



Page 23 of 25

Ecodesign requirem	Pass			
Model identification		NL-BKDX50-200II/R32		
Declared temperature application		Exception of low-temperature		
Items	Measured value	Stage 1	Stage 2	Verdict
seasonal space heating energy efficiency ๆ s	128,4	⊠ From 26 September 2015 ≥100	⊠ From 26 September 2017 ≥110	Pass

Declared temperature	application	low-temperature		
Items	Measured value	Stage 1	Stage 2	Verdict
seasonal space heating energy efficiency η s	179,4	⊠ From 26 September 2015 ≥115	⊠ From 26 September 2017 ≥125	Pass





Photo documents:

Products General







Page 25 of 25 Report No.: GZES201203564132





--- End of Report ---